



CICERO FIRE DEPARTMENT

FIRE CODE ENFORCEMENT

1359 Stringtown Pike • Cicero, IN 46034
Telephone: 317-984-4575 • Fax: 317-984-7309

Hydrant Compliance

507.5.4 Obstruction. Unobstructed access to fire hydrants shall be maintained at all times. The fire department shall not be deterred or hindered from gaining immediate access to fire protection equipment or fire hydrants.

507.5.5 Clear space around hydrants. A 3-foot (914mm) clear space shall be maintained around the circumference of fire hydrants, except as otherwise required or *approved*.